

EQUIPMENT DATA SPECIFICATION

AIR CONDITIONER NE030

Hazardous Location Systems



TABLE OF CONTENTS

- 1.0 SCOPE
- 2.0 REQUIREMENTS
- 3.0 OPTIONS
- 4.0 ACCESSORIES
- 5.0 CODES AND STANDARDS

SPECIFICATION

1.0 SCOPE

This specification covers the minimum general and specific requirements for the Air Conditioner unit for electrical enclosures used in hazardous locations.

2.0 REQUIREMENTS

•	Type of Heat Exchange	Compressor based air conditioner
---	-----------------------	----------------------------------

• Ambient Operating Temperature $60^{\circ}\text{F} - 122^{\circ}\text{F}$

• Approvals and Stamps _CUL_{US} (Safety), _CMET_{US} (Haz Loc), CE

Area Classification
Class I, Division 2, Groups A, B, C & D, T4

• UL Type 4X

Voltage
103.5-126.5 VAC, 60 Hz, 23.42A Inrush, 5.15A Running

207-253 VAC, 60 Hz, 13.65A Inrush, 3.07A Running 414-506 VAC, 60 Hz, 5.86A Inrush, 1.3A Running

• BTU Rating 3000 BTUH, Nominal

Material Type
304 stainless steel housing, #4 Finish

Construction
Chassis: Rigid, insulated, closed loop

Shroud: Seam welded, sloped top, insulated

• Refrigeration Circuit Protection Electrostatic epoxy coated condenser coil

• Condensate Removal Active evaporation utilizing superheated refrigerant coil

• Refrigerant R422d

Refrigerant Metering Thermal expansion valve

(High Temperature Warning)

High pressure Refrigerant Service Ports Low pressure Condenser high pressure switch **Compressor Protection** Evaporator low pressure switch Digital Controller o Controls Cooling set point Cooling set point differential o Auxiliary set point: Dry contact Auxiliary set point differential o Display Enclosure air temperature Compressor Head Pressure Control Pressure controlled condenser fan switch **Compressor Protection** Thermal/current overload switch (self-resetting) Standard: Expanded aluminum, 250 micron, 60% efficiency Condenser Filter **Electrical Connection** Terminal block 115 V / 230 V: 32"H x 11.8"W x 9.5"D **Dimensions** 460 V: 38"H x 11.8"W x 9.5"D 115 V: 66 lbs. Unit Weight 230 V: 72 lbs. 460 V: 99 lbs. Corrugated packaging and pallet Shipping 5 years Warranty 3.0 **OPTIONS** Material Type 316 stainless steel housing, #4 Finish Electrostatic epoxy coated evaporator coil Refrigeration Circuit Protection Epoxy coated refrigeration tubing High Capacity Condenser Filter 2" Pleated, 304 Stainless steel mesh, 250 micron, 94% efficiency 304 or 316 Stainless Steel Louvered Security Filter Cover Low Ambient For operation at ambient temperatures below 60°F **Dry Contact** Normally open

• Custom Programming Factory programming of digital controller for Celsius

temperature or deviation from default settings

• Extended Temperature Probe Monitor & maintain temperature at any point inside equipment

enclosure

• Remote Controller Digital controller supplied with 10 ft. cable & bracket for

installation inside equipment cabinet

Vibration Package
Protects air conditioner components from effects of moderate or

severe vibration

4.0 ACCESSORIES

Replacement Filters Standard

High Capacity

5.0 CODES AND STANDARDS

• ANSI/UL 484 Room Air Conditioners (Special Purpose)

• UL508A Industrial Control Panels (Complies when installed with

UL508A approved industrial control panels)

ANSI/NFPA 70
National Electrical Code

• CSA-C22.2 No. 236-M90 Heating and Cooling Equipment

CSA-C22.2 No. 117
Room Air Conditioners (Special Purpose)

CAN/CSA-C22.1 Canadian Electrical Code, Part I.

• Harmonized European Standards

EN 378-1 through -4
EN 60204-1
Refrigerating Systems and Heat Pumps
Electrical Equipment of Machinery

o EN 60529, IP IP Code

o EN 61000-3-11 Electromagnetic Compatibility

○ EN 61000-6-2 Emission
○ EN 61000-6-4 Immunity

o 2011/65/EU Restriction of the use of certain hazardous substances in

electrical and electronic equipment

Hazardous Location Standards

o ANSI/ISA-12.12.01-2015 Nonincendive Electrical Equipment for use in Class I and II,

Division 2 and Class III, division 1 and 2 Hazardous (Classified)

Locations

o CAN/CSA C22.2 No. 213-15 Nonincendive Electrical Equipment for use in Class I and II,

Division 2 and Class III, Division 1 and 2 Hazardous

(Classified) Locations