

## AIR CONDITIONER PRODUCT LINE (J4)

Thermal Edge 50 Hz Hazardous Location air conditioners are certified to the following standard(s): ANSI/ISA-12.12.01-2015 Nonincendive Electrical Equipment for use in Class I, Division 2, Groups A, B, C and D Hazardous (Classified) Locations; CAN/CSA C22.2 No. 213-15 Nonincendive Electrical Equipment for use in Class I, Division 2, Groups A, B, C and D Hazardous (Classified) Locations.

Model	BTU/Hour	Voltage/ Phase/Hz	Maximum Ambient Temp	Temp. Code
CS020235	2,000	230/1/50	48°C	T6
NE020105	2,000	100/1/50	50°C	T4
NE020235	2,000	230/1/50	50°C	T4
NE020385	2,000	380/1/50	50°C	T4
NE020405	2,000	400/1/50	50°C	T4
NE020415	2,000	415/1/50	50°C	T4
NE030105	3,000	100/1/50	50°C	T4
NE030205	3,000	200/1/50	50°C	T4
NE030385	3,000	380/1/50	50°C	T4
NE030405	3,000	400/1/50	50°C	T4
NE030415	3,000	415/1/50	50°C	T4
NE050235	5,000	230/1/50	50°C	T4
NE050385	5,000	380/1/50	50°C	T4
NE050405	5,000	400/1/50	50°C	T4
NE050415	5,000	415/1/50	50°C	T4
NE060235	6,000	230/1/50	50°C	T4
NE060385	6,000	380/1/50	50°C	T4
NE060405	6,000	400/1/50	50°C	T4
NE060415	6,000	415/1/50	50°C	T4
HC080235	8,000	230/1/50	50°C	T4
HC080385	8,000	380/1/50	50°C	T4
HC080405	8,000	400/1/50	50°C	T4
HC080415	8,000	415/1/50	50°C	T4
HC101235	10,000	230/1/50	50°C	T4
HC101385	10,000	380/1/50	50°C	T4
HC101405	10,000	400/1/50	50°C	T4
HC101415	10,000	415/1/50	50°C	T4
HC121235	12,000	230/1/50	50°C	T4
HC121385	12,000	380/1/50	50°C	T4
HC121405	12,000	400/1/50	50°C	T4
HC121415	12,000	415/1/50	50°C	T4